

	SON VU Technical Service Co., Ltd. Quang Phu, Phu My Town, Tan Thanh District, BRVT province Tel: (+84 64) 2215987-215988 Fax: (+84 64) 3895593 Email: sonvuco@yahoo.com.vn	Customer: Ca Mau
		MS No. MS-SV-126
		Date: 20 rd July 2015

QUALITY PLAN

<p><u>SCOPE FOR:</u></p> <p style="text-align: center;">HRSG TUBES CLEANING SERVICES</p> <p style="text-align: center;">Customer: Ca Mau Power Company Ltd.</p> <p style="text-align: center;">Date of Service: July – Aug 2015</p> <p style="text-align: center;">Location: Ca Mau Power Plant</p>
--

(H) – Hold that mean the work only be continue when the Client Supervisor confirmation
(W) – Witness that means only the Contractor Supervisor checks and ensures the task finished and good quality
(FW) – Final Witness that mean the Client Supervisor and Contractor Supervisor doing the final check.

Task Item	Check sheet	Witness			Note	Signature
		H	W	FW		
Identify and Mark before separating of the tubes		X				
After cleaning of front side of module 5 by compressed air			X			
After cleaning of back side of module 5 by compressed air		X				
After cleaning of front side of module 6 by compressed air			X			
After cleaning of back side of module 6 by compressed air		X				
After cleaning of front side of module 7 by compressed air			X			
After cleaning of back side of module 7 by compressed air		X				
Clean all the dust, dirt, deposit and the scale on the floors of all modules			X			
House keeping			X			
Final check				X		